

2013 Report

WATER QUALITY RELATIVE TO PUBLIC HEALTH GOALS

June 2013



PADRE DAM
Municipal Water District

Background

SB 1307, added to the California Health and Safety Code in 1997, specifies that water utilities with more than 10,000 service connections prepare a special report if their water quality measurements have exceeded any Public Health Goal (PHG) established by the California Environmental Protection Agency, or in the absence of a PHG, the Maximum Contaminant Level Goal (MCLG) established by the United States Environmental Protection Agency (USEPA).

The report must be completed by July 1 every three years, beginning in 1998, and must be followed by a public hearing for the purpose of accepting and responding to public comment on the report. This public hearing will be scheduled as part of Padre Dam Municipal Water District's regular Board meeting on July 17, 2013, and will be noticed as required.

Padre Dam's water supply complies with all of the health-based drinking water standards and maximum contaminant levels (MCLs) required by the California Department of Public Health (CDPH) and the USEPA.

Reporting Requirements

The California Health and Safety Code, Section 116470 (b) (SB 1307) specifies that this report must include (See Attachment 1):

- Identify any constituent in Padre Dam's water supply between 2010 and 2012 exceeding an applicable PHG or MCLG;
- Include the category or type of health risk that could be associated with each identified constituent;
- Include the numerical public health risk associated with the PHG, MCLG or Maximum Contaminant Level (MCL);
- Identify the best treatment technology available to reduce the constituent level;
- Estimate the cost to install that treatment if it is appropriate and feasible.

The report only addresses constituents which have a California Primary Drinking Water Standard for which either a PHG or MCLG has been set (See Attachment 2). There are constituents, such as Total Trihalomethanes, for which the California Environmental Protection Agency (Cal/EPA) or USEPA have not yet adopted a PHG or MCLG. The few constituents in this category are routinely detected in water systems, but usually at levels well below drinking water standards. These constituents will be addressed when a PHG is adopted.

Public Health Goals

PHGs are set by the California Office of Environmental Health Hazard Assessment (OEHHA), which is part of Cal/EPA, and are based solely on public health risk considerations. None of the practical risk-management factors – including detection capability, available treatment technology, and costs versus benefits -- that are considered by the USEPA or the California Department of Public Health (CDPH) in setting drinking water standards (MCLs) are considered in setting the PHGs. The PHGs are not enforceable and are not required to be met by any public water system. MCLGs are the federal equivalent to PHGs.

Water Quality Data Used

Padre Dam receives its water supply from three treatment facilities: Metropolitan Water District of Southern California's (MWD) Skinner Water Treatment Plant, Helix Water District's (Helix) R. M. Levy Treatment Plant, and the San Diego County Water Authority's (SDCWA) Twin Oaks Valley Treatment Plant.

This report is based on all water quality data collected by Padre Dam from our distribution system and our water suppliers from 2010 through 2012 to determine compliance with drinking water standards. This data was summarized in Padre Dam's 2010, 2011 and 2012 Water Quality Reports.

Guidelines Followed

Padre Dam used the guidelines developed by The Association of California Water Agencies (ACWA) to prepare this report.

Best Available Treatment Technologies and Cost Estimates

Both the USEPA and the CDPH adopt Best Available Technologies (BATs), the best practices available to reduce contaminant levels to the MCL, the highest level of a contaminant allowed in drinking water. Data is available to estimate the cost of installing these technologies. (see Attachment 2)

It is not always possible or feasible, however, to determine what treatment and technology is needed to reduce a constituent level to the PHG or MCLG, which is set much lower than the MCL, and is often set at zero. Estimating the costs to reduce a constituent to zero is difficult, if not impossible, because analytical means to verify that the level has been lowered to zero may not be available. In some cases, installing treatment to further reduce very low levels of one constituent may have adverse effects on other aspects of water quality.

Constituents Detected That Exceed a PHG or MCLG

The following constituents were detected in Padre Dam's drinking water supply at some point between 2010 and 2012 at levels above the PHG, or if no PHG, above the MCLG.

Total Coliform Bacteria

Coliform bacteria exist naturally and are not generally considered harmful. They are monitored because they are indicator organisms. If a positive sample is found, it indicates a potential problem that needs to be investigated. It is not at all unusual for a water system to have an occasional positive sample. It is difficult, if not impossible, to assure that a system will never have a positive sample.

The MCL for coliform is 5%, which means that a maximum of 5% of water samples per month can be positive for coliform. The MCLG is zero. The reason for the coliform drinking water standard is to minimize the possibility of the water containing pathogens -- organisms that cause waterborne disease. Because coliform is only a surrogate indicator of the potential presence of pathogens, it is not possible to state a specific numerical health risk. While USEPA normally sets MCLGs "at a level where no known or

anticipated adverse effects on persons would occur”, they are unable to do so with coliforms.

In 2010, Padre Dam collected between 104 and 130 samples per month for coliform analysis. Occasionally, a sample was found to be positive for coliform bacteria but recheck samples were negative and follow-up actions were taken. A maximum of 3.6% of monthly samples were positive in any month. E. Coli was not detected in any samples.

In 2011, Padre Dam collected between 104 and 130 samples per month. All samples were found to be negative for coliform bacteria.

In 2012, Padre Dam collected between 104 and 130 samples per month for coliform analysis. Occasionally, a sample was found to be positive for coliform bacteria but recheck samples were negative and follow-up actions were taken. A maximum of 1.81% of monthly samples were positive in any month. E. Coli was not detected in any samples.

Padre Dam has taken all of the steps described by CDPH as Best Available Technology (BATs) for coliform bacteria in Section 64447, Title 22, CCR.

We have worked closely with our regional treated water suppliers, Metropolitan Water District of Southern California, San Diego County Water Authority and Helix Water District, to provide for a slightly higher disinfectant residual. Residual levels are carefully controlled to provide the best health protection without causing the water to have undesirable taste and odor or increasing the disinfection byproduct level.

In addition, Padre Dam has implemented an effective cross-connection control program and a comprehensive monitoring and security system to protect the integrity of Padre Dam’s water distribution system and the quality of water delivered to our customers. Lastly, we work to maintain positive water pressure and adequate disinfectant residual throughout the system.

Arsenic

Arsenic is a naturally occurring element in the earth's crust and is very widely distributed in the environment. All humans are exposed to microgram quantities of arsenic (inorganic and organic) largely from food (25 to 50 µg/day) and to a lesser degree from drinking water and air. In certain geographical areas, natural mineral deposits may contain large quantities of arsenic and this may result in higher levels of arsenic in water.

The MCL for arsenic is 10 ppb, the PHG and MCLG for arsenic is 0.0004 ppb. Arsenic was detected at the SDCWA Twin Oaks Valley Plant in a Single Sample in 2011(2.4 ppb) and 2012(3.6 ppb). The Helix Levy Plant reported a range of Non Detect – 2.2 for Arsenic levels in 2011.

The OEHHA has set the PHG at 4 ppt (0.0004 ppb). The category of health risk for Arsenic is carcinogenicity. The PHG is based on a level that will result in not more than 1 excess cancer in 1 million people who drink 2 liters daily of this water for 70 years. The actual cancer risk may be lower or zero.

Reverse osmosis is one of the most effective BATs that is used to reduce levels below the MCL. It would be difficult to measure RO's effectiveness in meeting PHG levels because the DLR (2ppb) for arsenic is greater than the PHG limit (0.004ppb). Padre Dam does not treat our potable water and therefore would have to rely on MWD, Helix and SDCWA treatment facilities to add this process. The estimated cost for reverse osmosis for arsenic removal is \$1.56 - \$3.64 per 1,000 gallons of water treated. This would be approximately \$6.1 - \$14.2 million dollars per year for water that Padre Dam purchases or approximately \$275-\$650 per Padre Dam water customer each year.

Gross Alpha

Radionuclides such as alpha in water supplies are from erosion of natural deposits. The term radionuclide refers to naturally occurring elemental radium, radon, uranium, and thorium with unstable atomic nuclei that spontaneously decay producing ionizing radiation. Gross alpha is defined as the sum total of these radionuclides.

The EPA's Maximum Contaminant Level Goal (MCLG) for gross alpha article is 0 and the California MCL is 15 pCi/L(picocuries per liter of water). The chart below shows results for gross alpha.

The health risk category for Gross Alpha is carcinogenicity. The MCLG for Gross Alpha is zero (0) therefore the cancer risk at the MCLG is zero.

Gross Beta

Gross Beta Particle Activity is naturally occurring in water purchased from our water suppliers. It is found in water from the decay of natural and man-made deposits.

The USEPA has determined that the health risk associated with the Maximum Contaminant Level Goal is 0.

Gross beta was detected above the MCLG of zero (0) in water purchased from MWD, Helix and SDCWA. However, all water samples were below the MCL.

Strontium 90

Strontium-90 is a radioactive isotope of strontium. It is produced by nuclear fission with a half life of 28.8 years. Strontium-90 is found in waste from nuclear reactors.

The category of health risk for Strontium-90 is carcinogenicity. The OEHHA has set the PHG at 0.35pCi/L. The numerical health risk is based on the California PHG for Strontium 90 is 1 in one million.

Strontium 90 was detected above the PHG of 0.35 pCi/L in the range of samples from the SDCWA Twin Oaks valley Plant in 2010. However, all water samples were significantly below the MCL of 8.

Uranium

Uranium is a naturally-occurring radioactive element present in geological formations and the earth's crust. It is introduced into groundwater and surface water through erosion.

The PHG for uranium is 0.43 pCi/L. The MCL for uranium is 20 pCi/L.

The OEHHA's health risk category for uranium is carcinogenicity and chronic toxicity (kidneys). Carcinogenic risk means capable of producing cancer. Chronic toxicity means that adverse effects may develop gradually from low levels of exposure over a long period of time. The numerical health risk for uranium based on the California PHG is 1 in a million. This means one excess cancer case per 1,000,000 population.

All of Padre Dam's water suppliers recorded low levels of uranium in 2010, 2011 and 2012:

Skinner Treatment Plant (MWD)

	PHG/MCLG	MCL	Range	Average
2010	0.43 pCi/L	20 pCi/L	2.3 – 2.7	2.5
2011			ND – 2	1
2012			ND – 2	1

Levy Treatment Plant (Helix WD)

	PHG/MCLG	MCL	Range	Average
2010	0.43 pCi/L	20 pCi/L	1.6 – 4.6	3.1
2011			ND – 1	1
2012			ND – 1	ND

Twin Oaks Valley Treatment Plant (SDCWA)

	PHG/MCLG	MCL	Range	Average
2010	0.43 pCi/L	20 pCi/L	2.5 – 4.1	3.3
2011			1 – 2.1	1.5
2012			1.0 – 1.7	1.3

Reverse osmosis is the BAT to lower the level of uranium and other radionuclides (Gross Alpha, Gross beta, Strontium-90) in Padre Dam's drinking water supply. Because Padre Dam does not operate its own water treatment plant, the cost to implement reverse osmosis (RO) treatment is based on the installation and operation of a reverse osmosis treatment system at each of the two connections through which Padre Dam receives already treated water from the San Diego County Water Authority. It would cost approximately \$1.56-\$3.64 per 1000 gallons to treat uranium using RO treatment. This would be approximately \$6.1 - \$14.2 million dollars per year for water that Padre Dam purchases or approximately \$275 - \$650 per Padre Dam water customer each year.

Bromate

Bromate is formed when naturally occurring bromide reacts with ozone during the disinfection process.

The category of health risk for bromate is carcinogenicity. Carcinogenic risk means capable of producing cancer. The numerical health risk based on the California PHG for bromate is 1 in a million. This means one excess cancer case per one million population.

The BAT for bromate reduction is reverse osmosis (RO). RO treatment reduces the natural occurring bromide in source water by reducing the natural organic matter (NOM) in water. When this is reduced, the demand for ozone decreases, therefore reducing bromate formation. Because the DLR for bromate (5 ppb) is greater than the PHG (0.1ppb), it would be difficult to assess the effectiveness of RO treatment on reaching the PHG level.

Bromate in our water system comes from our treated water from MWD, SDCWA and Helix water treatment plants. It would not be feasible for Padre Dam to lower bromate levels to the PHG and MCLG levels because it meets federal and state health-based standards. According to the Association of California Water Agencies (ACWA) Cost Estimates for Treatment Technology BAT, it would cost approximately \$1.56 - \$3.64 per 1,000 gallons of water treated to remove bromate. This would be approximately \$6.1 - \$14.2 million dollars per year for water that Padre Dam purchases or approximately \$275-\$650 per Padre Dam water customer each year.

Lead and Copper

There is no MCL for Lead or Copper. Instead the 90th percentile value of all samples from household taps in the distribution system cannot exceed an Action Level of 0.015 mg/l for lead and 1.3 mg/l for copper. The PHG for lead is 0.002 mg/l. The PHG for copper is 0.17 mg/l.

The category of health risk for lead is damage to the kidneys or nervous system of humans. The category of health risk for copper is gastrointestinal irritation. Numerical health risk data on lead and copper have not yet been provided by OEHHA, the State agency responsible for providing that information.

Padre Dam's water system is in full compliance with the Federal and State Lead and Copper Rule. Based on our extensive sampling, it was determined according to State regulatory requirements that we meet the Action Levels for Lead and Copper.

In general, optimizing corrosion control is considered to be the best available technology to deal with corrosion issues and with any lead or copper findings. We continue to monitor our water quality parameters that relate to corrosivity, such as the pH, hardness, alkalinity, total dissolved solids, and will take action if necessary to maintain our system in an "optimized corrosion control" condition.

Since Padre Dam is meeting the "optimized corrosion control" requirements, it is not prudent to initiate additional corrosion control treatment as it involves the addition of

other chemicals and there could be additional water quality issues raised. Therefore, no estimate of cost has been included.

N-Nitrosodimethylamine (NDMA)

NDMA is a drinking water contaminant that is of interest to the environmental community because of its miscibility with water, as well as its carcinogenicity and toxicity.

The category of health risk for NDMA is carcinogenicity. The OEHHA has set the PHG at 3 ppt (0.0003 ppb). The PHG is based on a level that will result in not more than 1 excess cancer in 1 million people who drink 2 liters daily of this water for 70 years. The actual cancer risk may be lower or zero.

The most common method to treat NDMA in drinking water systems is photolysis by ultraviolet (UV) radiation in the wavelength range of 225 to 250 nanometers (nm).

NDMA in Padre Dam's water system comes from our treated water from MWD, SDCWA and Helix water treatment plants. It would not be feasible for Padre Dam to lower NDMA levels unless all three of our water suppliers treatment plants were to implement a UV process. Currently NDMA meets federal and state health-based standards. According to the Association of California Water Agencies (ACWA) Cost Estimates for UV Treatment, it would cost approximately \$0.51 per 1000 gallons to NMDA using Advanced Oxidation or UV Light treatment. This would be approximately \$2 million dollars per year for water that Padre Dam purchases or approximately \$90 per Padre Dam water customer each year.

Recommendations for Further Action

Padre Dam's drinking water quality meets all California Department of Health Services and USEPA drinking water standards set to protect public health.

To further reduce the levels of the constituents identified in this report -- which are already below the health-based Maximum Contaminant Levels established to provide "safe drinking water" would require additional costly treatment processes. The effectiveness of the treatment processes to provide any significant reductions in constituent levels at these already low values is uncertain. Further, the health protection benefits of these further hypothetical reductions are not at all clear and may not be quantifiable. Therefore, no further action is recommended at this time.

The money that would be required for these additional treatment processes might provide greater public health protection benefits if spent on other water system operations, surveillance, and monitoring programs.

Attachments

1. Table of Regulated Constituents with MCLs, PHGs or MCLGs
2. Excerpt from California Health & Safety Code: Section 116470 (b)
3. Cost Estimates Chart

ATTACHMENT No. 1

2013 PHG Triennial Report: Calendar Years 2010-2011-2012

MCLs, DLRs, and PHGs for Regulated Drinking Water Contaminants
(Units are in milligrams per liter (mg/L), unless otherwise noted.)

Last Update: February 12, 2013

(Reference: <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/MCLsandPHGs.aspx>)

This table includes:

- CDPH's maximum contaminant levels (MCLs)
- CDPH's detection limits for purposes of reporting (DLRs)
- [Public health goals \(PHGs\) from the Office of Environmental Health Hazard Assessment \(OEHHA\)](#)
- PHGs for NDMA and 1,2,3-Trichloropropane (1,2,3-TCP is unregulated) are at the bottom of this table
- The federal MCLG for chemicals without a PHG, microbial contaminants, and the DLR for 1,2,3-TCP

Constituent	MCL	DLR	PHG or (MCLG)	Date of PHG
Chemicals with MCLs in 22 CCR §64431—Inorganic Chemicals				
Aluminum	1	0.05	0.6	2001
Antimony	0.006	0.006	0.02	1997
Arsenic	0.010	0.002	0.000004	2004
Asbestos (MFL = million fibers per liter; for fibers >10 microns long)	7 MFL	0.2 MFL	7 MFL	2003
Barium	1	0.1	2	2003
Beryllium	0.004	0.001	0.001	2003
Cadmium	0.005	0.001	0.00004	2006
Chromium, Total - OEHHA withdrew the 1999 0.0025 mg/L PHG in Nov 2001	0.05	0.01	(0.100)	
Chromium, Hexavalent (Chromium-6) - MCL to be established - currently regulated under the total chromium MCL	--	0.001	0.00002	2011
Cyanide	0.15	0.1	0.15	1997
Fluoride	2	0.1	1	1997
Mercury (inorganic)	0.002	0.001	0.0012	1999 (rev2005)*
Nickel	0.1	0.01	0.012	2001
Nitrate (as NO ₃)	45	2	45	1997
Nitrite (as N)	1 as N	0.4	1 as N	1997
Nitrate + Nitrite	10 as N	0.4	10 as N	1997
Perchlorate	0.006	0.004	0.006	2004
Selenium	0.05	0.005	0.03	2010
Thallium	0.002	0.001	0.0001	1999 (rev2004)
Copper and Lead, 22 CCR §64672.3				
<i>Values referred to as MCLs for lead and copper are not actually MCLs; instead, they are called "Action Levels" under the lead and copper rule</i>				
Copper	1.3	0.05	0.3	2008
Lead	0.015	0.005	0.0002	2009

ATTACHMENT No. 1

Constituent	MCL	DLR	PHG or (MCLG)	Date of PHG
Radionuclides with MCLs in 22 CCR §64441 and §64443—Radioactivity				
[units are picocuries per liter (pCi/L), unless otherwise stated; n/a = not applicable]				
Gross alpha particle activity - OEHHA concluded in 2003 that a PHG was not practical	15	3	(zero)	n/a
Gross beta particle activity - OEHHA concluded in 2003 that a PHG was not practical	4 mrem/yr	4	(zero)	n/a
Radium-226	--	1	0.05	2006
Radium-228	--	1	0.019	2006
Radium-226 + Radium-228	5	--	(zero)	--
Strontium-90	8	2	0.35	2006
Tritium	20,000	1,000	400	2006
Uranium	20	1	0.43	2001
Chemicals with MCLs in 22 CCR §64444—Organic Chemicals				
(a) Volatile Organic Chemicals (VOCs)				
Benzene	0.001	0.0005	0.00015	2001
Carbon tetrachloride	0.0005	0.0005	0.0001	2000
1,2-Dichlorobenzene	0.6	0.0005	0.6	1997 (rev2009)
1,4-Dichlorobenzene (p-DCB)	0.005	0.0005	0.006	1997
1,1-Dichloroethane (1,1-DCA)	0.005	0.0005	0.003	2003
1,2-Dichloroethane (1,2-DCA)	0.0005	0.0005	0.0004	1999 (rev2005)
1,1-Dichloroethylene (1,1-DCE)	0.006	0.0005	0.01	1999
cis-1,2-Dichloroethylene	0.006	0.0005	0.1	2006
trans-1,2-Dichloroethylene	0.01	0.0005	0.06	2006
Dichloromethane (Methylene chloride)	0.005	0.0005	0.004	2000
1,2-Dichloropropane	0.005	0.0005	0.0005	1999
1,3-Dichloropropene	0.0005	0.0005	0.0002	1999 (rev2006)
Ethylbenzene	0.3	0.0005	0.3	1997
Methyl tertiary butyl ether (MTBE)	0.013	0.003	0.013	1999
Monochlorobenzene	0.07	0.0005	0.2	2003
Styrene	0.1	0.0005	0.0005	2010
1,1,2,2-Tetrachloroethane	0.001	0.0005	0.0001	2003
Tetrachloroethylene (PCE)	0.005	0.0005	0.00006	2001
Toluene	0.15	0.0005	0.15	1999
1,2,4-Trichlorobenzene	0.005	0.0005	0.005	1999
1,1,1-Trichloroethane (1,1,1-TCA)	0.2	0.0005	1	2006
1,1,2-Trichloroethane (1,1,2-TCA)	0.005	0.0005	0.0003	2006
Trichloroethylene (TCE)	0.005	0.0005	0.0017	2009
Trichlorofluoromethane (Freon 11)	0.15	0.005	0.7	1997
1,1,2-Trichloro-1,2,2-Trifluoroethane (Freon 113)	1.2	0.01	4	1997 (rev2011)
Vinyl chloride	0.0005	0.0005	0.00005	2000
Xylenes	1.75	0.0005	1.8	1997

ATTACHMENT No. 1

Constituent	MCL	DLR	PHG or (MCLG)	Date of PHG
Chemicals with MCLs in 22 CCR §64444—Organic Chemicals				
(b) Non-Volatile Synthetic Organic Chemicals (SOCs)				
Alachlor	0.002	0.001	0.004	1997
Atrazine	0.001	0.0005	0.00015	1999
Bentazon	0.018	0.002	0.2	1999 (rev2009)
Benzo(a)pyrene	0.0002	0.0001	0.000007	2010
Carbofuran	0.018	0.005	0.0017	2000
Chlordane	0.0001	0.0001	0.00003	1997 (rev2006)
Dalapon	0.2	0.01	0.79	1997 (rev2009)
1,2-Dibromo-3-chloropropane (DBCP)	0.0002	0.00001	0.0000017	1999
2,4-Dichlorophenoxyacetic acid (2,4-D)	0.07	0.01	0.02	2009
Di(2-ethylhexyl)adipate	0.4	0.005	0.2	2003
Di(2-ethylhexyl)phthalate (DEHP)	0.004	0.003	0.012	1997
Dinoseb	0.007	0.002	0.014	1997 (rev2010)
Diquat	0.02	0.004	0.015	2000
Endrin	0.002	0.0001	0.0018	1999 (rev2008)
Endothal	0.1	0.045	0.58	1997
Ethylene dibromide (EDB)	0.00005	0.00002	0.00001	2003
Glyphosate	0.7	0.025	0.9	2007
Heptachlor	0.00001	0.00001	0.000008	1999
Heptachlor epoxide	0.00001	0.00001	0.000006	1999
Hexachlorobenzene	0.001	0.0005	0.00003	2003
Hexachlorocyclopentadiene	0.05	0.001	0.05	1999
Lindane	0.0002	0.0002	0.000032	1999 (rev2005)
Methoxychlor	0.03	0.01	0.00009	2010
Molinate	0.02	0.002	0.001	2008
Oxamyl	0.05	0.02	0.026	2009
Pentachlorophenol	0.001	0.0002	0.0003	2009
Picloram	0.5	0.001	0.5	1997
Polychlorinated biphenyls (PCBs)	0.0005	0.0005	0.00009	2007
Simazine	0.004	0.001	0.004	2001
2,4,5-TP (Silvex)	0.05	0.001	0.025	2003
2,3,7,8-TCDD (dioxin)	3x10 ⁻⁸	5x10 ⁻⁹	5x10 ⁻¹¹	2010
Thiobencarb	0.07	0.001	0.07	2000
Toxaphene	0.003	0.001	0.00003	2003

ATTACHMENT No. 1

Constituent	MCL	DLR	PHG or (MCLG)	Date of PHG
Chemicals with MCLs in 22 CCR §64533—Disinfection Byproducts				
Total Trihalomethanes	0.080	--	--	--
Bromodichloromethane	--	0.0010	(zero)	--
Bromoform	--	0.0010	(zero)	--
Chloroform	--	0.0010	(0.07)	--
Dibromochloromethane	--	0.0010	(0.06)	--
Haloacetic Acids (five) (HAA5)	0.060	--	--	--
Monochloroacetic Acid	--	0.0020	(0.07)	--
Dichloroacetic Acid	--	0.0010	(zero)	--
Trichloroacetic Acid	--	0.0010	(0.02)	--
Monobromoacetic Acid	--	0.0010	--	--
Dibromoacetic Acid	--	0.0010	--	--
Bromate	0.010	0.0050 or 0.0010 ^a	0.0001	2009
Chlorite	1.0	0.020	0.05	2009
Microbiological Contaminants (TT = Treatment Technique)				
Coliform % positive samples	%	5	(zero)	
<i>Cryptosporidium</i> **		TT	(zero)	
<i>Giardia lamblia</i> **		TT	(zero)	
<i>Legionella</i> **		TT	(zero)	
Viruses**		TT	(zero)	
Chemicals with PHGs established in response to CDPH requests. These are <u>not</u> currently regulated drinking water contaminants.				
N-Nitrosodimethylamine (NDMA)	--	--	0.000003	2006
1,2,3-Trichloropropane	--	0.000005	0.000007	2009

Notes:

^a CDPH will maintain a 0.0050 mg/L DLR for bromate to accommodate laboratories that are using EPA Method 300.1. However, laboratories using EPA Methods 317.0 Revision 2.0, 321.8, or 326.0 must meet a 0.0010 mg/L MRL for bromate and should report results with a DLR of 0.0010 mg/L per Federal requirements.

*OEHHA's review of this chemical during the year indicated (rev20XX) resulted in no change in the PHG

** Surface water treatment = TT

NOTE: This publication is meant to be an aid to the staff of the CDHS Drinking Water Program and cannot be relied upon by the regulated community as the State of California's representation of the law. The published codes are the only official representation of the law. Refer to the published codes whenever specific citations are required.

Health and Safety Code §116470

(a) As a condition of its operating permit, every public water system shall annually prepare a consumer confidence report and mail or deliver a copy of that report to each customer, other than an occupant, as defined in Section 799.28 of the Civil Code, of a recreational vehicle park. A public water system in a recreational vehicle park with occupants as defined in Section 799.28 of the Civil Code shall prominently display on a bulletin board at the entrance to or in the office of the park, and make available upon request, a copy of the report. The report shall include all of the following information:

(1) The source of the water purveyed by the public water system.

(2) A brief and plainly worded definition of the terms "maximum contaminant level," "primary drinking water standard," and "public health goal."

(3) If any regulated contaminant is detected in public drinking water supplied by the system during the past year, the report shall include all of the following information:

(A) The level of the contaminant found in the drinking water, and the corresponding public health goal and primary drinking water standard for that contaminant.

(B) Any violations of the primary drinking water standard that have occurred as a result of the presence of the contaminant in the drinking water and a brief and plainly worded statement of health concerns that resulted in the regulation of that contaminant.

(C) The public water system's address and phone number to enable customers to obtain further information concerning contaminants and potential health effects.

(4) Information on the levels of unregulated contaminants, if any, for which monitoring is required pursuant to state or federal law or regulation.

(5) Disclosure of any variances or exemptions from primary drinking water standards granted to the system and the basis therefor.

(b) On or before July 1, 1998, and every three years thereafter, public water systems serving more than 10,000 service connections that detect one or more contaminants in drinking water that exceed the applicable public health goal, shall prepare a brief written report in plain language that does all of the following:

(1) Identifies each contaminant detected in drinking water that exceeds the applicable public health goal.

(2) Discloses the numerical public health risk, determined by the office, associated with the maximum contaminant level for each contaminant identified in paragraph (1) and the numerical public health risk determined by the office associated with the public health goal for that contaminant.

(3) Identifies the category of risk to public health, including, but not limited to, carcinogenic, mutagenic, teratogenic, and acute toxicity, associated with exposure to the contaminant in drinking water, and includes a brief plainly worded description of these terms.

(4) Describes the best available technology, if any is then available on a commercial basis, to remove the contaminant or reduce the concentration of the contaminant. The public water system may, solely at its own discretion, briefly describe actions that have been taken on its own, or by other entities, to prevent the introduction of the contaminant into drinking water supplies.

NOTE: This publication is meant to be an aid to the staff of the CDHS Drinking Water Program and cannot be relied upon by the regulated community as the State of California's representation of the law. The published codes are the only official representation of the law. Refer to the published codes whenever specific citations are required.

(5) Estimates the aggregate cost and the cost per customer of utilizing the technology described in paragraph (4), if any, to reduce the concentration of that contaminant in drinking water to a level at or below the public health goal.

(6) Briefly describes what action, if any, the local water purveyor intends to take to reduce the concentration of the contaminant in public drinking water supplies and the basis for that decision.

(c) Public water systems required to prepare a report pursuant to subdivision (b) shall hold a public hearing for the purpose of accepting and responding to public comment on the report. Public water systems may hold the public hearing as part of any regularly scheduled meeting.

(d) The department shall not require a public water system to take any action to reduce or eliminate any exceedance of a public health goal.

(e) Enforcement of this section does not require the department to amend a public water system's operating permit.

(f) Pending adoption of a public health goal by the Office of Environmental Health Hazard Assessment pursuant to subdivision (c) of Section 116365, and in lieu thereof, public water systems shall use the national maximum contaminant level goal adopted by the United States Environmental Protection Agency for the corresponding contaminant for purposes of complying with the notice and hearing requirements of this section.

(g) This section is intended to provide an alternative form for the federally required consumer confidence report as authorized by 42 U.S.C. Section 300g-3(c).

ATTACHMENT NO. 3

Table 3

Reference: 2010 ACWA Cost of Treatment Table, Costs Revised for 2012

COST ESTIMATES FOR TREATMENT TECHNOLOGIES

(INCLUDES ANNUALIZED CAPITAL AND O&M COSTS)

No.	Treatment Technology	Source of Information	Estimated 2012* Unit Cost (\$/1,000 gallons treated)
1	Granular Activated Carbon	Reference: Malcolm Pirnie estimate for California Urban Water Agencies, large surface water treatment plants treating water from the State Water Project to meet Stage 2 D/DBP and bromate regulation, 1998	0.53-1.00
2	Granular Activated Carbon	Reference: Carollo Engineers, estimate for VOC treatment (PCE), 95% removal of PCE, Oct. 1994,1900 gpm design capacity	0.24
3	Granular Activated Carbon	Reference: Carollo Engineers, est. for a large No. Calif. surf. water treatment plant (90 mgd capacity) treating water from the State Water Project, to reduce THM precursors, ENR construction cost index = 6262 (San Francisco area) - 1992	1.16
4	Granular Activated Carbon	Reference: CH2M Hill study on San Gabriel Basin, for 135 mgd central treatment facility for VOC and SOC removal by GAC, 1990	0.45-0.66
5	Granular Activated Carbon	Reference: Southern California Water Co. - actual data for "rented" GAC to remove VOCs (1,1-DCE), 1.5 mgd capacity facility, 1998	2.08
6	Granular Activated Carbon	Reference: Southern California Water Co. - actual data for permanent GAC to remove VOCs (TCE), 2.16 mgd plant capacity, 1998	1.35
7	Reverse Osmosis	Reference: Malcolm Pirnie estimate for California Urban Water Agencies, large surface water treatment plants treating water from the State Water Project to meet Stage 2 D/DBP and bromate regulation, 1998	1.56-2.99
8	Reverse Osmosis	Reference: Boyle Engineering, RO cost to reduce 1000 ppm TDS in brackish groundwater in So. Calif., 1.0 mgd plant operated at 40% of design flow, high brine line cost, May 1991	3.69
9	Reverse Osmosis	Reference: Boyle Engineering, RO cost to reduce 1000 ppm TDS in brackish groundwater in So. Calif., 1.0 mgd plant operated at 100% of design flow, high brine line cost, May 1991	2.27
10	Reverse Osmosis	Reference: Boyle Engineering, RO cost to reduce 1000 ppm TDS in brackish groundwater in So. Calif., 10.0 mgd plant operated at 40% of design flow, high brine line cost, May 1991	2.46
11	Reverse Osmosis	Reference: Boyle Engineering, RO cost to reduce 1000 ppm TDS in brackish groundwater in So. Calif., 10.0 mgd plant operated at 100% of design flow, high brine line cost, May 1991	1.90
12	Reverse Osmosis	Reference: Arsenic Removal Study, City of Scottsdale, AZ - CH2M Hill, for a 1.0 mgd plant operated at 40% of design capacity, Oct. 1991	6.17

COST ESTIMATES FOR TREATMENT TECHNOLOGIES
(INCLUDES ANNUALIZED CAPITAL AND O&M COSTS)

No.	Treatment Technology	Source of Information	Estimated 2012* Unit Cost (\$/1,000 gallons treated)
13	Reverse Osmosis	Reference: Arsenic Removal Study, City of Scottsdale, AZ - CH2M Hill, for a 1.0 mgd plant operated at 100% of design capacity, Oct. 1991	3.64
14	Reverse Osmosis	Reference: Arsenic Removal Study, City of Scottsdale, AZ - CH2M Hill, for a 10.0 mgd plant operated at 40% of design capacity, Oct. 1991	2.73
15	Reverse Osmosis	Reference: Arsenic Removal Study, City of Scottsdale, AZ - CH2M Hill, for a 10.0 mgd plant operated at 100% of design capacity, Oct. 1991	1.69
16	Reverse Osmosis	Reference: CH2M Hill study on San Gabriel Basin, for 135 mgd central treatment facility with RO to remove nitrate, 1990	1.70-2.99
17	Packed Tower Aeration	Reference: Analysis of Costs for Radon Removal... (AWWARF publication), Kennedy/Jenks, for a 1.4 mgd facility operating at 40% of design capacity, Oct. 1991	0.98
18	Packed Tower Aeration	Reference: Analysis of Costs for Radon Removal... (AWWARF publication), Kennedy/Jenks, for a 14.0 mgd facility operating at 40% of design capacity, Oct. 1991	0.52
19	Packed Tower Aeration	Reference: Carollo Engineers, estimate for VOC treatment (PCE) by packed tower aeration, without off-gas treatment, O&M costs based on operation during 329 days/year at 10% downtime, 16 hr/day air stripping operation, 1900 gpm design capacity, Oct. 1994	0.26
20	Packed Tower Aeration	Reference: Carollo Engineers, for PCE treatment by Ecolo-Flo Enviro-Tower air stripping, without off-gas treatment, O&M costs based on operation during 329 days/year at 10% downtime, 16 hr/day air stripping operation, 1900 gpm design capacity, Oct. 1994	0.27
21	Packed Tower Aeration	Reference: CH2M Hill study on San Gabriel Basin, for 135 mgd central treatment facility - packed tower aeration for VOC and radon removal, 1990	0.42-0.69
22	Advanced Oxidation Processes	Reference: Carollo Engineers, estimate for VOC treatment (PCE) by UV Light, Ozone, Hydrogen Peroxide, O&M costs based on operation during 329 days/year at 10% downtime, 24 hr/day AOP operation, 1900 gpm capacity, Oct. 1994	0.51
23	Ozonation	Reference: Malcolm Pirnie estimate for CUWA, large surface water treatment plants using ozone to treat water from the State Water Project to meet Stage 2 D/DBP and bromate regulation, <i>Cryptosporidium</i> inactivation requirements, 1998	0.12-0.24
24	Ion Exchange	Reference: CH2M Hill study on San Gabriel Basin, for 135 mgd central treatment facility - ion exchange to remove nitrate, 1990	0.57-0.74

Note: *Costs were adjusted from date of original estimates to present, where appropriate, using Engineering News Record (ENR) building costs index (20-city average) from Dec 2012.